



## PURCHASING DIVISION

Charlotte County Administration Center  
18500 Murdock Circle  
Port Charlotte, Florida 33948-1094

Telephone (941) 743-1378  
Facsimile (941) 743-1384

OCTOBER 07, 2009

TO: PROSPECTIVE BIDDERS

RE: BID 2009000345, SOUTH GULF COVE ENTRY FEATURE

ADDENDUM NO. 3 BID DUE DATE: OCTOBER 14, 2009 @ 2:00 PM, EST

Bidders are hereby notified that this addendum shall be made a part of the above-named proposal and contract documents. The following is issued to modify, and/or clarify the proposal and contract documents. These items shall have the same force and effect as the original bid and contract documents, and bids to be submitted on the specified date shall conform with the additions, deletions and revisions as listed herein.

### ITEM #1 QUESTIONS/ANSWERS:

Q1. What is the correct amount of Palm Trees required for this project? The plans call for five (5) each behind each monument, twelve (12) palms per street times four (4) entrances should equal sixty-eight (68) total. The summary of pay items has a total of fifty-eight (58)?

A1. The summary of pay items is fifty-eight (58) palm trees for the supplemental landscape portion. This includes twelve (12) trees at two (2) locations and seventeen (17) trees at the other two (2) locations totaling fifty-eight (58). These trees are separate from the five (5) trees associated with each sign as they are lump sums to complete the signs at four (4) locations totaling twenty (20) trees and shall be included in the lump sum price for each sign on the bid form.

Q2. Section B-B (Sheet S-100) – See section B-B Sheet S-101 – does not show trim. Also in this section, what finish do we need to use on the blocks?

A2. Sheet S-102 defines trim and finish on blocks along with color. All masonry shall receive a one (1) inch thick cementuous coating.

Q3. Elevation view (Sheet S-100) – all block columns and lower front wall do not show how they have to be finished.

A3. All masonry to receive a one (1) inch thick cementuous coating.

Q4. On the plans is doesn't show where the electric power is to come from please clarify?

A4. On plan set page C-101, under general notes, please refer to note number seven (7) and eight (8).

This addendum is binding and is to be considered as if contained within the original bid documents of Bid No. 2009000345. Bidders are required to acknowledge receipt of this addendum on their bid forms.

Kimberly A. Corbett, C.P.M., CPPB  
Senior Division Manager - Purchasing

KAC/acm

cc: Clerk's Office, Minutes Division  
File

BID NO. 2009000345, ADDENDUM #3